

CERTIFICATE OF APPROVAL
No. ME0102

This is to certify that the referenced products of

Middle East Metal and Wood Industries Co Ltd.

P.O Box 502, Riyadh 11383, Kingdom of Saudi Arabia
Tel: +966 1 265 0 666 Fax: +966 1 265 0 688

have been assessed against the requirements of the *warringtonfire – mideast certification scheme* and are approved for use within the scope of the test and/or assessment report(s) referenced.

Timber Based FD30 Doorsets

**30 Minutes Integrity and Insulation Performances In Accordance
With BS 476: Part 22: 1987**

Assessment Report Reference	Valid Until
Report WF No. 173489	1 st February 2014

Approved Maximum Door Leaf Dimensions			
Configuration	Leaf Height (mm)	Leaf Width (mm)	Leaf Area (m²)
Latched, Single-Acting, Single-Leaf, 50 mm thick	2632 (At 1072 wide)	1179 (At 2393 high)	2.82
Latched, Single-Acting, Double-Leaf, 50 mm thick (note: inactive leaf flush bolted top & bottom, active leaf latched to inactive leaf at mid-height)	2632 (At 1072 wide)	1179 (At 2393 high)	2.82

Page 1 of 3

Certification is awarded on the basis of initial type testing and assessment to BS 476: Part 22: 1987, initial inspection and ongoing surveillance of factory production control, and ongoing compliance with the scheme requirements including the use of labels supplied by Bodycote **warringtonfire**. The currency of the certification may be verified at www.warringtonfire.net/mideast

Signed for and on behalf of Warrington Certification



Sir Ken Knight
Chairman - Management Council

Issued: 6th January 2009
Valid to: 5th January 2014

Summary of Fire Assessment Chilt/A06039



Issue Date 3 April 2006

For: **Metalco**
Middle East Metal & Wood Industries Co Ltd
PO Box 502
Riyadh 11383
Kingdom of Saudi Arabia

Chiltern House Stocking Lane Hughenden Valley
High Wycombe Buckinghamshire HP14 4ND UK

t +44 (0) 1494 569800 f +44 (0) 1494 564895
e cif@chilternfire.co.uk w www.chilternfire.co.uk

PRODUCT DESCRIPTION

Metalco FD30 - 30 minute fire resisting doorsets comprising the following:

Door leaves with hardwood stiles and rails surrounding a chipboard core and fitted in to hardwood door frames.

Summary

It is our opinion that, the Metalco doorsets complying with the specification detailed in Chiltern International Fire assessment report Chilt/A06039, would achieve the following performance, if tested in accordance with BS476: Part 22: 1987:

Integrity: 30 minutes

Insulation: 30 minutes (Doorsets including less than 20% of non-insulating glazing)

Validity

This assessment summary is valid until 29 March 2011 (the validity period of Chilt/A06039), after which time it is recommended that it be submitted to Chiltern International Fire Ltd for re-appraisal.

Prepared by:

A handwritten signature in black ink, appearing to read "J P Mullett".

J P Mullett
Principal Consultant

Checked by:

A handwritten signature in black ink, appearing to read "K D S Towler".

K D S Towler
Principal Consultant

The summarised information given above outlines the overall scope of the assessment. It is the responsibility of the user to ensure that all requirements of the full assessment report are followed. Chiltern International Fire Ltd accept no responsibility for errors arising from use of this summary.
