

**CERTIFICATE OF APPROVAL**  
**No. ME0115**

This is to certify that the referenced products of

**Middle East Metal and Wood Industries Co Ltd.**

P.O Box 502, Riyadh 11383, Kingdom of Saudi Arabia  
Tel: +966 1 265 0 666 Fax: +966 1 265 0 688

have been assessed against the requirements of the *warringtonfire – mideast certification scheme* and are approved for use within the scope of the test and/or assessment report(s) referenced.

**Mineral Composite Based FD120 Doorsets**

**120 Minutes Integrity and 108 Minutes Insulation Performances**  
**In Accordance With BS 476: Part 22: 1987**

<b>Assessment Report Reference</b>	<b>Valid Until</b>
Report WF No. 173490	1 <sup>st</sup> February 2014

<b>Approved Maximum Door Leaf Dimensions</b>			
<b>Configuration</b>	<b>Leaf Height (mm)</b>	<b>Leaf Width (mm)</b>	<b>Leaf Area (m<sup>2</sup>)</b>
Latched, Single-Acting, Single-Leaf, 62 mm thick	2330 (At 1045 wide)	1150 (At 2119 high)	2.44
Latched, Single-Acting, Double-Leaf, 62 mm thick  (note: inactive leaf flush bolted top & bottom, active leaf latched to inactive leaf at mid-height)	2650 (At 1045 wide)	1306 (At 2119 high)	2.44

Page 1 of 3

Certification is awarded on the basis of initial type testing and assessment to BS 476: Part 22: 1987, initial inspection and ongoing surveillance of factory production control, and ongoing compliance with the scheme requirements including the use of labels supplied by Bodycote **warringtonfire**. The currency of the certification may be verified at [www.warringtonfire.net/mideast](http://www.warringtonfire.net/mideast)

**Signed for and on behalf of Warrington Certification**



Sir Ken Knight  
Chairman - Management Council

Issued: 6<sup>th</sup> February 2009  
Valid to: 5<sup>th</sup> February 2014